

R.Balasubramanian,
Secretary

To
The Chairman,
Tamil Nadu Electricity Board,
144, Anna Salai,
Chennai – 600 002.

Lr. No. TNERC/D(E)/AD/SA/F.Rel. Index/D.No. 483 /2009 Dt. 15.4.2008

Sir,

Sub: TNERC – Declaration of Reliability Index (RI) as per section 5.13.2 of National Electric policy – Reg.

- Ref :** (1) **TNERC** Lr. No. TNERC/D(E)/AD/SA/F.Rel. Index/D.No. 483/2008 Dt. 15.4.2008
(2) **TNEB** Lr.No.CFC/GL/Dir/Tf.Cell/AEE/F.QR//D.714-13/08 dt 6.10.08.
(3) **TNEB** Lr No. CFC/Rev./Dir/Tf.Cell/AEE/F.Qr/D.714-6 /07 dt. 21.3.2007
(4) **TNERC** Lr. No. TNERC/D(E)/DD(E)/AD/SA/F.NEP/D.No. 050/2007 Dt. 11.4.2007.
(5) **TNERC** Lr. No. TNERC/D(E)/DD(E)/AD/SA/F.NEP/D.No. 330 / 2007 Dt. 30.5.2007.
(6) **TNEB** Lr. No. CE/Plg/SE/APDRP/EE/AEE/F.TNERC(RI)/ D.158 / 2006 dt. 11.8.2007
(7) **TNERC** Lr. No. TNERC/D(E)/DD(E)/AD/SA/F.NEP/D.No. 760 /2007 Dt.30.8.2007.
(8) **TNERC** Lr. No. TNERC/D(E)/DD(E)/AD/SA/F.NEP/D.No. 044 /2008 Dt.18.1.2008.
(9) **TNEB** Lr. No. CE/Plg/SE/APDRP/EE/AEE/F.TNERC(RI)/ D.22 / 2006 dt. 6.2.2008

* * * * *

With reference to the above, I am directed to communicate the following:

1. In line with Section 5.13.2 of the National Electric Policy, the Reliability Index as approved by the Commission for all the cities, towns up to district headquarters and rural areas is as given below:

Category	Reliability Index in %
----------	------------------------

	2007-08	2008-09	2009-10	2010-11	2011-12
Cities	99.40	99.60	99.80	99.90	99.95
Towns up to District headquarters	99.10	99.40	99.60	99.80	99.95
Rural areas	95	96.25	97.5	98.25	99.00

2. TNEB is directed to adhere to the above stipulations of the Commission.

Secretary
Tamil Nadu Electricity Regulatory Commission