

**TAMIL NADU ELECTRICITY REGULATORY COMMISSION**  
**(Constituted under Section 82 (1) of the Electricity Act, 2003**  
**Central Act 36 of 2003)**

**PRESENT:-**

**Thiru.K.Venugopal** ..... **Member**

**Thiru.S.Nagalsamy** ..... **Member**

**M.P. No. 35 of 2012**

TANGEDCO ..... Petitioner  
Thiru. P.H. Vinod Pandian, Standing Counsel

Versus

Nil ..... Respondent

**Hearing date : 27-2-2013**

**DAILY ORDER**

Chief Engineer, Planning and R& C explained that 100% meters in feeders will be completed by March 2013 and these meters will be read regularly. As far as 100% metering in Distribution Transformer is concerned, DT meters covered under RAPDRP totalling to 40,500 meters will be provided with AMR facilities. Existing meters and additional meters will be equipped with AMR features while installing the meters for DT. Priority will be given to installation of such meters for Distribution Transformers feeding agriculture and hut services, so that consumption by these consumers can be reasonably arrived at. The petitioner has been directed to furnish the details with regard to arriving at 4.5% as Transmission loss upto 11kv Bus and the Government response to the letter addressed by them in April 2012. This information shall be furnished within 15 days. Arguments concluded. Orders reserved.

(Sd.....)  
**(S. Nagalsamy)**  
**Member**

(Sd.....)  
**(K. Venugopal)**  
**Member**

/ True Copy /

**Secretary**  
**Tamil Nadu Electricity**  
**Regulatory Commission**